



In any correspondence relating to this report please quote:

District **L624**

Policy **RES/28325**

Item No. **L1**

## REPORT OF THOROUGH EXAMINATION OF LIFTING EQUIPMENT

Lifting Operations and Lifting  
Equipment Regulations 1998  
(Regulation 9)

---

1	<i>Employer (and/or plant owner)</i>	<b>Great Cliff (Dawlish) Ltd</b>
2	<i>Address</i>	<b>S3809 GREAT CLIFF MARINE PARADE DAWLISH DEVON EX7 9EX</b>
3	<i>Address at which the examination was made</i>	<b>As above</b>
4	<i>Description of Lifting Equipment</i>	<b>ELECTRIC HYDRAULIC PASSENGER LIFT</b>
	<i>Distinguishing Number</i>	<b>250457</b>
	<i>Makers Name</i>	<b>STANNAH</b>
	<i>Model</i>	
	<i>Year of Manufacture</i>	<b>Unknown</b>
	<i>Safe Working Load (As marked, unless otherwise stated)</i>	<b>630kg / 8 Persons</b>
5	<i>Nature of Examination</i>	<b>Thorough Examination carried out within an interval of 6 months under Regulation 9(3)(a)(i) unless otherwise indicated.</b>
6	<i>Identification of any part found to have a defect which is or could become a danger to persons. State description of the defect, and any repair, renewal or alteration required to remedy the defect, either immediately or within a specified time.</i>	<b>None.</b>
7 (i)	<i>Other defects and remedies</i>	<b>The auto-dialler is inoperative with both the power on and isolated. To be investigated and repaired.</b>
7 (ii)	<i>Details of any tests required to supplement the examination</i>	<b>None.</b>
8	<i>Observations</i>	<b>The suspension ropes show wear but remain serviceable.</b>  <b>The Safety Assessment Federation (SAFed) give guidance on supplementary testing of in-service lifts and some of these tests are recommended on a 'periodic' basis and should be considered as part of your routine service regime. We advise the key safety aspects of this lift installation be risk assessed and consideration be given to 'periodic' testing, where applicable, in accordance with the</b>

---

current version of SAFed lift guidelines (LG1). Where supplementary tests are required to support the thorough examination a request will be made by the competent person.

**Note: Design not checked, this report should be read in conjunction with an EC Declaration of Conformity Certificate and/or Initial Thorough Examination Report (inc. load test, where applicable) issued by your manufacturer and/or installer.**

---

9	Date of last thorough examination	<b>28/07/2023</b>
	Date of this examination	<b>15/04/2024</b>
	Latest date by which the next thorough examination must be carried out	<b>15/10/2024</b>

---


Unless otherwise stated, this inspection has been completed in accordance with Procedure 05-20-P01.

I certify that the above equipment was thoroughly examined (unless otherwise stated) and, subject to any remedial action to defects noted on this report, which are or could become a danger to persons, the equipment is safe to operate.

Date of Examination **15/04/2024**

Report Date **15/04/2024**

Signature: Mr J Dunn



Qualification - Engineer Surveyor to  
British Engineering Services  
Unit 718 Eddington Way, Birchwood Park, Warrington WA3 6BA  
Telephone: 0345 712 5842 Web: britishengineeringservices.co.uk

**L3**

vers E.72  
ID: 39429797



9230