



Ideal Lifts Service Ltd  
 Unit 5D Cranmere Road  
 Exeter Road Industrial Estate  
 Okehampton  
 Devon,  
 EX20 1UE  
 01837 659 734  
[service@ideallifts.com](mailto:service@ideallifts.com)  
[www.ideallifts.com](http://www.ideallifts.com)

## SAFed LG1 4.2

### Covering certificate of supplementary tests

Unique report reference ID:	58278
Owner/Occupier of premises:	Great Cliff
Address:	Marine Parade, Dawlish, Devon, EX7 9EX
Type of lift(s) and description:	Stannah Passenger Hydraulic, 2 Floors (G,1) 375kg
Owner's Identification Number(s):	Unknown
Manufacturer's Serial Number(s) (If known):	250457
Location of lift(s):	Main Entrance

Annex A.1 - EARTH CONTINUITY Reference clause 4.1	PASS
Annex A.2 - ELECTRIC SAFETY DEVICES Reference clause 4.2	PASS
Annex A.3 - TERMINAL SPEED REDUCTION SYSTEMS Reference clause 4.3	N/A
Annex A.4 - LANDING DOOR INTERLOCKS Reference clause 4.4	PASS
Annex A.7 - OVERSPEED GOVERNORS Reference clause 4.6 and 4.6.1	N/A
Annex A.8 - GOVERNOR OPERATED SAFETY GEAR INSTANTANEOUS TYPE Ref clause 4.6 and 4.6.2	N/A
Annex A.9 - GOVERNOR OPERATED SAFETY GEAR PROGRESSIVE TYPE Reference clause 4.6, 4.6.3	N/A
Annex A.10 - SAFETY GEAR OPERATED BY OTHER MEANS Reference clause 4.6 and 4.6.4	PASS
Annex A.12 - UNINTENDED CAR MOVEMENT PROTECTION MEANS Reference clause 4.8	N/A
Annex A.13 - ENERGY DISSIPATION BUFFERS Reference clause 4.9	N/A
Annex A.14 - SUSPENSION SYSTEM Reference clause 4.10	PASS
Annex A.15 - CAR OVERLOAD DETECTION WARNING DEVICES Reference clause 4.11	N/A
Annex A.16 - HYDRAULIC SYSTEM Reference clause 4.12	PASS
Annex A.17 - HYDRAULIC CYLINDERS IN BOREHOLES OR SIMILAR LOCATIONS Reference clause 4.12.1	N/A
Annex A.18 - HYDRAULIC RUPTURE / RESTRICTOR VALVES Reference clause 4.12.2	PASS
Annex A.19 - ELECTRICAL ANTI-CREEP DEVICE Reference clause 4.13 and 4.13.1	PASS
Annex A.20 - MECHANICAL ANTI-CREEP DEVICE (PAWL OR CLAMPING DEVICE) Ref clause 4.13 & 4.13.2	N/A
Annex A.21 - LOW PRESSURE DETECTION DEVICES Reference clause 4.14	PASS
Annex A.24 - AUTOMATIC POWER OPERATED DOORS Reference clause 4.17	PASS
Annex A.25 - OTHER SUPPLEMENTARY TESTS Reference clause 4.18	N/A

To be completed by the person or corporate body carrying out the supplementary test.

Signed Position	IDEAL LIFTS SERVICE LTD
Print Name	IDEAL LIFTS SERVICE LTD
Lift I.D. / Ref	IDLS0042
Date of tests(s)	06/03/2025
Date of certificate	10/03/2025

Key code: **PASS – no issues** **PASS – attention required** **FAIL – advice to follow** **N/A – not applicable to the lift**